



सत्यमेव जयते

Government Of West Bengal
Office Of The Divisional Fire Officer, Purba Medinipur
West Bengal Fire & Emergency Services
Dharinda, P.O.- Tamluk, Purba Medinipur, Pin:- 721636

Memo no.:FSR/0125186231400045

Date: 26-10-2023

From:
Divisional Fire Officer, Purba Medinipur
West Bengal Fire & Emergency Services

To: INSTITUTE OF EDUCATION HALDIA
At-Amlat , P.o.-Sutahata , Dist.-Purba Medinipur ,

Sub: Fire Safety Certificate for existing construction G+II Storied Building under group of Educational Building in the name & style of "INSTITUTE OF EDUCATION HALDIA" at Premises Dag No.- 780, JL No.- 89, Mouza- Amlat, PO+PS- Sutahat, District- Purba Medinipur- 721635.

This is in reference to your application no. 0125189231400172 dated 13-10-2023 regarding the Fire Safety Certificate for existing construction G+II Storied Building under group of Educational Building in the name & style of "INSTITUTE OF EDUCATION HALDIA" at Premises Dag No.- 780, JL No.- 89, Mouza- Amlat, PO+PS- Sutahat, District- Purba Medinipur- 721635.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

Conditional Fire safety certificate allow, subject to provide the 3rd stair (which recommended for overcome the dead end of this educational establishment and marked in sanctioned Plan) with in Six month positively and informed to this end by written with photograph for regularization the same for next terms.

Except the above the General recommendation are as follows.-

- 1) Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No Parking will be allowed on the Driveway.
- 2) Proposed Stair which marked in plan shall be completed from ground floor up-to the roof within 3 months otherwise this certificate will be treated as cancelled.
- 3) LPG Gas bank shall be made outside the Kitchen and kitchen shall be protected with CO2 extinguisher.

- 4)Exit ways shall be marked properly and all exit ways shall remain open during working hours.
- 5)The Interior finish decoration of building shall be made with low flame spread material conforming to the IS Specification.
- 6)To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 7)Electrical wiring of the whole building shall have to be carefully checked for any where any tear in them, particularly lines having false ceiling and ducts,
- 8)The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building.
- 9)The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
- 10)Mock Fire Practice and evacuation drill shall be performed periodically with Participants of all the occupants of the building.
- 11)Meter room shall be protected with Co2 Fire Extinguisher conforming IS specification,
- 12)First-Aid Fire Fighting system shall be provided as per I.S specification.
- 13)Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
- 14)Periodical flashing of water in the Hose Reel Hose line shall be made to maintain the efficiency working performance of above mention system.
- 15)If required the old lines shall have to be replace with new lines cables shall always be laid in M.S. conduct pipes continuously bounded to the earth,
- 16)The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
- 17)Revised Fire Safety Recommendation shall be applied for any addition & alternation made in the structure.
- 18)This Fire Safety Certificate is valid for three years and has to be renewed in every three years from the date of issue of this letter Vide Notification No.- 629_L dated 17.04.2018 and Memo No.- WBFES/604(200)/2919 dated 01.02.2019.
- 19)The Renewal Fire Safety Certificate is to be obtained from the Divisional Fire Officer, Purba Medinipur Division, West Bengal Fire and Emergency Services performance of all the life and Fire Safety arrangements and installations of the building.

Divisional Fire Officer, Purba Medinipur
West Bengal Fire & Emergency Services

Memo No.: FSR/0125186231400045